

CITY OF PALM SPRINGS ENGINEERING DIVISION
WATER MAIN PLAN CHECK SHEET
Revised September 30, 2009

I. Preparation of Plan Sheets

1. Per Desert Water Agency, Mission Springs Water District, or Coachella Valley Water District requirements with block for City Engineer signature "For Location Only"

II. Plan

1. Show alignment and dimensioned location of water line on plan. Show all utilities and obstructions.
2. Water line to be a minimum of 10 feet horizontally from outside of sewer. If less than 10' from sewer main refer to the State of California, Department of Health Services - Criteria For The Separation Of Water Mains and Sanitary Sewers.
3. Show existing pavement widths (to edge of pavement or face of curb)
4. Show all existing survey monuments and bench marks within project area. Note on plans "Protect In Place" where applicable.
5. Place submitting Engineer's stamp/seal with expiration date, as well as his/her signature, on each plan sheet.
6. Show construction notes on all sheets.
7. **Existing features may be greyscaled, but no less than 40% black. Lines may be solid or dashed. No dotted lines are permitted for existing features.**